

Automatic Control Valve

Written Specification (Purchase Specs)

Model C601DW/CA601DW
CS601DW (Global EU Model)
Pump Control Valve
FULL PORTED

Sizes:

Globe: 1 1/2" - 30" (DN 40 - DN750)
Angle: 1 1/2" - 12" (DN40 - DN300)

Function:

The Pump Control Valve is installed on the discharge of booster pumps to eliminate downstream pressure surges caused by starting and stopping the pump. The valve shall have a single chamber and be normally closed. On pump start up a solenoid pilot is energized to open the valve at a controlled adjustable rate. Separate flow control valves allow for opening and closing speeds to be independently adjusted. The valve shall have a built in check feature to prevent reverse flow.

Main Valve Body:

The main valve shall be self contained hydraulically operated, single diaphragm-actuated globe or angled body valve with no pistons operating the valve or pilot controls. The valve shall have four major components: the body with seat installed, the cover with bushing installed, intermediate lower body with bearing installed and the diaphragm assembly. The diaphragm assembly shall be the only moving part. It shall form a seal between the intermediate body and cover chamber. An o-ring seal located in the intermediate chamber isolates the line pressure from the operating pressure. Packing glands and stuffing boxes are not permitted. The valve is designed for use with various types of pressure and/or electric controls to provide the desired control of pressure or flow for a variety of water system applications.

Description:

The valve body, intermediate body and cover shall be of cast material (Ductile Iron) with no fabrication or welding used in the manufacturing process.

The valve shall contain a resilient, synthetic rubber seat seal, with a rectangular cross-section contained on three and one half sides by the spool and seat plate, and form a tight seal against a single removable seat ring. No O-ring type seal (circular, square or quad type) shall be permitted as the seating surface. The seat plate shall be contoured to permit the smooth transition of flow and hold the seat seal firmly in place. The spool shall be of a sturdy one piece design capable of withstanding opening and closing shocks.

The diaphragm assembly contains a non-magnetic 304 stainless steel stem of sufficient diameter to withstand the high hydraulic pressure. It shall be fully guided at both ends and in the intermediate body for the entire range of travel, in the cover and intermediate body by removable bushings and in the valve by integral bearing in the valve seat ring. The valve shall be capable of modulating from a tightly closed position to a full open position unless a static condition or pressure reversal occurs. If a static or pressure reversal occurs the valve shall close to prevent reverse flow regardless of the position of the diaphragm. The stem shall be drilled and tapped in the cover end



to receive and affix such accessories as may be necessary. The diaphragm assembly shall be the only moving part and shall form a seal between the intermediate body and cover.

The non-wicking, flexible, FDA approved diaphragm shall consist of nylon fabric bonded with synthetic rubber compatible with the operating fluid. The diaphragm must withstand a Mullins burst Test of a minimum 600 psi per layer of nylon fabric. It shall be tested 100,000 times to insure longevity. The diaphragm shall be fully supported in the intermediate valve body and cover by machined surfaces with radius edges to prevent excessive wear as the diaphragm flexes. The support must be no less than one-half of the total surface area of the diaphragm in either the fully open or fully closed position.

The seat ring with integral bearing shall be a one-piece solid design and shall have a minimum of a 4° taper on the seating surface for a positive drip-tight shut off. The seat ring in 4" and smaller size valves shall be threaded into the body. The valve seat ring in 6" and larger sizes shall be retained by hex head bolts for ease of maintenance. The lower bearing of the valve stem shall be contained concentrically within the seat ring and be exposed to the flow on all sides to avoid deposits. Locating the valve body, intermediate body, and cover shall be by a machined locating lip to insure proper alignment of the valve stem. Pinning of the cover to the intermediate body and the intermediate body to the valve body shall not be permitted.

All necessary repairs and/or modifications other than replacement of the main valve body shall be made possible without removing the valve from the pipeline. The valve manufacturer shall warrant the valve to be free of defects in material and workmanship for a one year period from date of shipment, provided the valve is installed and used in accordance with all applicable instructions.

The valve manufacturer shall be able to supply a complete line of equipment from 1-1/2" through 30" sizes and a complete selection of complementary equipment. The valve manufacturer shall also provide a cavitation chart which shows flow rate, differential pressure, percentage of valve opening, Cv factor, system velocity and if there will be cavitation damage.

Material Specification

Valve size:
Main Valve Body and Cover:
Main Valve Trim:
Connection:
Pressure Rating:
Temperature Range:
Rubber Material:
Coating:
Desired Options:



Pilot Control System:

The pilot control shall have a four-way solenoid pilot with manual operator controlled by an external electrical power source utilizing line pressure for operation. Solenoid shall have a NEMA IV enclosure.

Limit Switch:

The adjustable limit switch indicator assembly shall be mounted on the main valve and be actuated by the opening and closing of the main valve stem. The limit switch shall be fully adjustable along any point of the main valves travel.

Material Specification for Pilot Control:

Pressure Rating:

Trim:

Rubber Material:

Tubing and Fittings:

Adjustment Range:

Operating Fluids:

Desired Options:

This valve shall be a Flomatic Model C601/CA601/CS601 Control Valve, as manufactured by Flomatic Corporation, Glens Falls, NY 12801.

